



NOTES:

- Before Installation, refer to Installation Instructions for 3-EVPWRA, 3-EVDVRA & 3-EVDVRX (P/N: 287434 Rev. 1.0 (3/2/1998))
- All circuits entering the annunciator enclosure must be power limited ad described in UL Standard 864, Section 24A.
- The number next to each switch & L.E.D., (I.E. SW1-2, 1-16), is used to locate the individual Switch or L.E.D. on
- the graphic panel. Please refer to the accompanyingnumbered artwork for the actual location of these devices.
- See the accompanying Excel Spreadsheet for detailed wiring information.

DRIVER DIAGRAM	KIRKLAND H. R. Phone: (8)	KIRKLAND CO., INC. 4935 Allison Street, Unit 13 Arvada, Colorado 80002 00) 247-2303 Fax: (303) 420-1856
EST 3-EVPWR POWER MODULE	DATE: 21 MAR 2003 BY GG	CAP-8646B
NEGATIVE FEED	REVISION: ORIGINAL	SHEET 2 OF 3

